



Burlington, WA *Corporate Laboratory (a)*
 1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400
 Bellingham, WA *Microbiology (b)*
 805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR *Microbiology/Chemistry (c)*
 9725 SW Commerce Cr Ste A2 - Wilsonville, OR 97070 - 503.682.7802
 Corvallis, OR *Microbiology/Chemistry (d)*
 1100 NE Circle Blvd, Ste 130 - Corvallis, OR 97330 - 541.753.4946
 Bend, OR *Microbiology (e)*
 20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425



Washington State Department of Health WATER BACTERIOLOGICAL ANALYSIS

Client Name: **Cascade River Park**
 P.O Box 141
 Marblemount, WA 98267

Reference Number: 23-38435
 Project: Coliform

System Name: CASCADE RIVER COMMUNITY CLUB
 System ID Number: 114940
 DOH Source Number: 00 - Distribution Sample (Bacteria)
 Sample Type: D - Drinking Water
 Sample Purpose: C - Compliance
 Sample Location: DI L 78
 County: Skagit
 Sampled By: Pixie Evans
 Sampler Phone: 360-873-2222

Repeat Sample Number:
 Lab Number: 164-77766
 Field ID: Bacteria
 Date Collected: 12/20/23 12:43
 Date Received: 12/20/23
 Date Set: 12/20/23 17:38
 Date Analyzed: 12/21/23 14:58
 Report Date: 12/22/23
 Comment: Cl2: 0.66
 Approved By: jln,mlh

Authorized by:

Jessica L Nunamaker
 Microbiologist/QA Officer

DOH#	PARAMETER	RESULT	Qualifier	UNITS	Analyst	METHOD	Batch	COMMENT
1	TOTAL COLIFORM	Satisfactory, Coliforms Absent		per 100mL	jln	SM9223 B	m_231220b	
3	E. COLI	Absent		per 100mL		SM9223 B	m_231220b	

If the sample is unsatisfactory you can get information at the following health department websites or phone numbers:

- Island Co: <http://www.islandcounty.net/health/Envh/DrinkingWater/index.htm>
- San Juan Co: <http://www.sanjuanco.com/health/ehswater.aspx>
- Skagit Co: http://www.skagitcounty.net/drinkingwater_ or 360-336-9380
- Snohomish Co: 425-339-5250
- Whatcom Co: http://www.co.whatcom.wa.us/health/environmental/drinking_water/index.jsp
- WSDOH: <http://www.doh.wa.gov/ehp/dw/Programs/coliform.htm>

NOTES:

If the result is Unsatisfactory, three (3) repeat samples and groundwater source samples are required for Group A Public Water Systems. Private individuals should investigate the cause of the unsatisfactory result and resample.
 If E. Coli or Fecal Coliform are present in sample do not drink the water until it is properly treated.

*If data qualifiers are present, see accompanying Qualifier Definition report.